Section **914** Page **101**Date **June 1, 2001**Supersedes Section 913 Page 101
Dated November 1, 199p

Application & Reference Data Typical Specifications

Section 914 Vertical Turbine Fire Pump

Section **914** Page **102** Date **June 1, 2001**

Supersedes Section 913 Page 102 Dated November 1, 199p

Typical Specifications

Vertical Turbine Fire Pump

Motor Driven

VE	RTICAL
	Contractor shall furnish and install a quantity of Aurora Pump stage, Model (Underwriters Laboratories Listed) (Underwriters Laboratories of Canada Listed) (Factory Mutual Approved) water lubricated vertical turbine fire pump(s). Each unit shall include a bowl assembly, strainer, column and shaft, surface discharge head, vertical hollow shaft electrical motor, automatic air release valve, discharge pressure gauge, and automatic motor controller.
(0	NDITIONS OF SERVICE
	The pump(s) shall be rated for GPM at PSI at the discharge head centerline. The maximum lift below (distance from the discharge head centerline to the minimum low water level) will not exceed feet. The distance from the top of the pump mounting pad to the bottom of the sump or reservoir shall be feet. The unit(s) will be installed at feet elevation above sea level with a maximum ambient temperature of degrees F.
	MP CONSTRUCTION CHARGE HEAD
	The discharge head shall be Class 30 cast iron with a separate cast iron foundation plate, and shall be furnished with a grease lubricated packing box and ANSI (125 lb.) (250 lb.) standard discharge flange. To prevent damage to the shaft when installing or removing the motor, a separate motor shaft shall be furnished and shall be connected to the headshaft at a point above the packing box with a threaded coupling. The headshaft shall be furnished with a stainless steel sleeve where it passes through the packing box. The discharge head shall be provided with a" NPT tap for packing box drainage. The discharge head shall be hydrostatically tested 1-1/2 times the maximum working pressure but in no case less than 250 PSI
(0	LUMN PIPE
	Pump column pipe shall be furnished in sections not exceeding 10 feet in length with straight threads and sleeve type couplings. Pipe weights shall be not less than specified in NFPA #20.
LIN	ESHAFT
	Open, water lubricated construction shall be used where the distance from the discharge head to the static water level does not exceed 50 feet. Lineshaft shall be furnished in sections not exceeding 10 feet in length. Lineshaft shall be SAE 1045 steel of adequate size to transmit the horsepower and thrust required and shall have renewable shaft sleeves. The lineshaft shall run in neoprene bearings housed in bronze bearing retainers.
BO	WL ASSEMBLY
	The pump bowls shall be Class 30 cast iron with bronze bowl wearing rings, bronze enclosed impellers and steel impeller lock collets. The pump shaft shall be 416 stainless steel supported by bronze bowl bearings. The bowl assembly shall be hydrostatically tested to 1-1/2 times the maximum working pressure but in no case less than 250 PSI. The bowl assembly shall be performance tested and certified performance curves supplied.
STF	RAINER
	A bronze basket strainer with a free area of at least 4 times the suction area and with openings to restrict the passage of a $1/2''$ sphere shall also be supplied.
ELE	CTRIC MOTOR
	Electric motor(s) shall be of the weather protected Type 1, vertical hollow shaft design with non-reverse ratchet and 1.15 service factor, RMP, and wound for phase, hertz, volts. Motor(s) shall be of the (across-the-line) (part-winding) (wye-delta) (primary resistor) (auto-transformer) (soft start) type starting and sizing so as not to exceed the permissible loading limits of NFPA #20 (or Factory Mutual Loss Prevention Data Sheet 3-7N) at any point on the pump performance curve. Motor(s) shall be provided with thrust bearings having an average life of 5 years continuous operation and capable of sustaining the maximum pump downthrust. Maximum motor horsepower shall not exceed HP.

CONTROLLER

The electric motor controller shall be arranged to start the fire pump motor automatically on loss of system pressure with (automatic stop) (manual stop). (For sprinkler or standpipe systems where an automatically controlled pumping unit constitutes the sole supply, the controller shall be wired for manual shutdown. Manual



Typical Specifications

Vertical Turbine Fire Pump

Motor Driven

Section **914** Page **103** Date **June 1, 2001**

Supersedes Section 913 Page 103 Dated November 1, 1999

shutdown shall also be provided where required by the authori phase, hertz, volts.	ity jurisdiction.) It shall be supplied with a circuit breaker rated not less than	AIC at
The magnetic starting contactor shall be of the (choose one:):		
1. Across-the-line type.	5. Wye-Delta open transition reduced voltage type.	
2. Primary resistor reduced voltage type.	6. Wye-Delta closed transition reduced voltage type.	
3. Primary reactor reduced voltage type.	7. Auto transformer reduced voltage type.	
4. Part winding reduced voltage start type.	8. Solid state soft start reduced voltage type.	

ACCESSORIES

Furnish each pump with the following fittings or accessories:

- 1. 3-1/2" dial discharge pressure gauge.
- 2. Minimum 1-1/2" automatic air and vacuum release valve.
- 3. Pressure recorder as required by Factory Mutual and NFPA #20, common to all pumps.
- 4. Hose valve manifold with a set of 2-1/2'' hose valves, caps and chains, or flowmeter common to all pumps.
- 5. Water level testing device common to all pumps.

STANDARDS

All equipment furnished and the complete installation shall be in accordance with NFPA #20 and/or (UL448) (ULC 448) (Factory Mutual Approved Standard #1312). Pump(s) and controller(s) shall bear the (UL) (ULC) (FM) mark.



Section **914** Page **104** Date **June 1, 2001**

Supersedes Section 913 Page 104 Dated November 1, 199p

Typical Specifications

Vertical Turbine Fire Pump

Engine Driven

•		۱ı				
١.	H١	M	ŀ	ĸ	Δ	ш

	Contractor shall furnish and install a quantity of Aurora Pump stage, Model (Underwriters Laboratories Listed) (Underwriters Laboratories of Canada Listed) (Factory Mutual Approved) water lubricated vertical turbine fire pump(s). Each unit shall include a bowl assembly, strainer, column and shaft, surface discharge head, vertical hollow shaft right angle gear, gear to engine flexible shaft with guard, automatic air release valve, discharge pressure gauge, and diesel engine with fuel and starting systems and automatic engine controller.
COI	IDITIONS OF SERVICE
	The pump(s) shall be rated for GPM at PSI at the discharge head centerline. The maximum lift below (distance from the discharge head centerline to the minimum low water level) will not exceed feet. The distance from the top of the pump mounting pad to the bottom of the sump or reservoir shall be feet. The unit(s) will be installed at feet elevation above sea level with a maximum ambient temperature of degrees F.
PUI	AP CONSTRUCTION
DIS	CHARGE HEAD
	The discharge head shall be Class 30 cast iron with a separate cast iron foundation plate, and shall be furnished with a grease lubricated packing box and ANSI (125 lb.) (250 lb.) standard discharge flange. To prevent damage to the shaft when installing or removing the motor, a separate motor shaft shall be furnished and shall be connected to the headshaft at a point above the packing box with a threaded coupling. The headshaft shall be furnished with a stainless steel sleeve where it passes through the packing box. The discharge head shall be provided with a

COLUMN PIPE

Pump column pipe shall be furnished in sections not exceeding 10 feet in length with straight threads and sleeve type couplings. Pipe weights shall be not less than specified in NFPA #20.

LINESHAFT

Open, water lubricated construction shall be used where the distance from the discharge head to the static water level does not exceed 50 feet. Lineshaft shall be furnished in sections not exceeding 10 feet in length. Lineshaft shall be SAE 1045 steel of adequate size to transmit the horsepower and thrust required and shall have renewable shaft sleeves. The lineshaft shall run in neoprene bearings housed in bronze bearing retainers.

BOWL ASSEMBLY

The pump bowls shall be Class 30 cast iron with bronze bowl wearing rings, bronze enclosed impellers and steel impeller lock collets. The pump shaft shall be 416 stainless steel supported by bronze bowl bearings. The bowl assembly shall be hydrostatically tested to 1-1/2 times the maximum working pressure but in no case less than 250 PSI. The bowl assembly shall be performance tested and certified performance curves supplied.

STRAINER

A bronze basket strainer with a free area of at least 4 times the suction area and with openings to restrict the passage of a 1/2" sphere shall also be supplied.

GEAR

A vertical hollow shaft right angle gear with a non-reverse ratchet shall be furnished to match the mounting dimensions of the discharge head. The gear shall have adequate thrust and horsepower ratings to transmit the maximum thrust and horsepower required by the pump.



Typical Specifications

Vertical Turbine Fire Pump

Engine Driven

Section **914** Page **105** Date **June 1, 2001**

Supersedes Section 913 Page 105 Dated November 1, 1999

ENGINE

Diesel engine(s) shall be equal to _____Model ____rated ____HP at _____RPM at 300 feet above sea level and 77 degrees F and shall be (Underwriters Laboratories Listed) (Factory Mutual Approved). Each engine shall be provided with electric starting equipment and a charging alternator. The factory supplied heat exchanger piping loop complete with required strainers, a pressure gauge, a pressure reducing valve, and a bypass line shall be installed between the pump discharge head and the engine heat exchanger by the installing contractor. Each engine shall be furnished with lead-acid starting batteries, battery rack and cables, a flexible exhaust connector and industrial type silencer. Furnish each engine with a jacket water heater.

FLEXIBLE SHAFT

A flexible shaft, with engine and gear flanges, shall be furnished to connect the engine to the gear. The shaft shall be adequately sized to transmit the maximum pump brake horsepower at the engine speed with a minimum bearing life of 2500 hours. The shaft shall be protected by a shaft guard.

CONTROLLER

The diesel engine controller shall be arranged to start the fire pump motor automatically on loss of system pressure with (automatic stop) (manual stop). (For sprinkler or standpipe systems where an automatically controlled pumping unit constitutes the sole supply, the controller shall be wired for manual shutdown. Manual shutdown shall also be provided where required by the authority jurisdiction.) An automatic weekly test timer shall also be standard. The controller shall be furnished with a built-in battery charger capable of restoring the batteries from a fully discharged condition to a fully charged condition within twenty-four (24) hours.

FUEL SYSTEM

Furnish an above ground fuel tank with a capacity equal to one gallon per horsepower plus 5% volume for expansion and 5% volume for sump. Furnish the tank with an indicating fuel level gauge. Provide flexible fuel line connectors at the engine and fuel line connections at the fuel tank. (Fuel lines to be provided by the installing contractor.)

ACCESSORIES

Furnish each pump with the following fittings or accessories:

- 1. 3-1/2" dial discharge pressure gauge.
- 2. Minimum 1-1/2" automatic air and vacuum release valve.
- 3. Main relief valve with closed waste cone.
- 4. Discharge tee with relief valve elbow.
- 5. Pressure recorder as required by Factory Mutual and NFPA #20, common to all pumps.
- 6. Hose valve manifold with a set of 2-1/2" hose valves, caps and chains, or flowmeter common to all pumps.
- 7. Water level testing device common to all pumps.

STANDARDS

All equipment furnished and the complete installation shall be in accordance with NFPA #20 and/or (UL448) (ULC 448) (Factory Mutual Approved Standard #1312). Pump(s) and controller(s) shall bear the (UL) (ULC) (FM) mark.



Section **914** Page **106** Date **May 1, 2004**

Supersedes Section 914 Page 106 Dated June 1, 2001

Technical Data

Vertical Turbine Fire Pump

	250 - 300 GPM 10 FEM											
NUMBER OF STAGES	4	5	6	7	8	9	10	11	12	13	14	15
Bowl O.D. (in.)	9.63	9.63	9.63	9.63	9.63	9.63	9.63	9.63	9.63	9.63	9.63	9.63
Bowl Kt/(lbs./Foot)	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8
Bowl Ka/(lbs.)	63.2	79	94.8	110.6	126.4	142.2	158	173.8	189.6	205.4	221.2	237
Bowl Shaft Diameter	1-7/16	1-7/16	1-7/16	1-7/16	1-7/16	1-7/16	1-7/16	1-7/16	1-7/16	1-7/16	1-7/16	1-7/16
Lineshaft Diameter (1)`	1	1	1	1	1	1-1/4	1-1/4	1-1/4	1-1/4	1-1/4	1-1/4	1-1/4
Lineshaft Ks/Foot	2.8	2.8	2.8	2.8	2.8	4.2	4.2	4.2	4.2	4.2	4.2	4.2
"SDC" Discharge Head Size (2)	16-1/2x6	16-1/2x6	16-1/2x6	16-1/2x6	N/A							
"LAD" Discharge Head Size (2)	16-1/2x6	16-1/2x6	16-1/2x6	16-1/2x6	16-1/2x6	16-1/2x6	16-1/2x6	16-1/2x6	16-1/2x6	16-1/2x6	16-1/2x6	16-1/2x6
Column O.D. (in.)	6-5/8	6-5/8	6-5/8	6-5/8	6-5/8	6-5/8	6-5/8	6-5/8	6-5/8	6-5/8	6-5/8	6-5/8
Column Weight/Foot (lbs.)	18.97	18.97	18.97	18.97	18.97	18.97	18.97	18.97	18.97	18.97	18.97	18.97
Column Wall Thickness (in.)	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28

400 GPM 10FEM											
NUMBER OF STAGES	4	5	6	7	8	9	10				
Bowl O.D. (in.)	9.63	9.63	9.63	9.63	9.63	9.63	9.63				
Bowl Kt/(lbs./Foot)	3.8	3.8	3.8	3.8	3.8	3.8	3.8				
Bowl Ka/(lbs.)	63.2	79	94.8	110.6	126.4	142.2	158				
Bowl Shaft Diameter	1-7/16	1-7/16	1-7/16	1-7/16	1-7/16	1-7/16	1-7/16				
Lineshaft Diameter (1)`	1	1	1	1	1	1-1/4	1-1/4				
Lineshaft Ks/Foot	2.8	2.8	2.8	2.8	2.8	4.2	4.2				
"SDC" Discharge Head Size (2)	16-1/2 x6	16-1/2 x6	16-1/2 x6	16-1/2 x6	N/A	N/A	N/A				
"LAD" Discharge Head Size (2)	16-1/2 x6										
Column O.D. (in.)	6-5/8	6-5/8	6-5/8	6-5/8	6-5/8	6-5/8	6-5/8				
Column Weight/Foot (lbs.)	18.97	18.97	18.97	18.97	18.97	18.97	18.97				
Column Wall Thickness (in.)	0.28	0.28	0.28	0.28	0.28	0.28	0.28				

	500 GPM 11FGM													
NUMBER OF STAGES														
Bowl O.D. (in.)	10.86	10.86	10.86	10.86	10.86	10.86	10.86	10.86	10.86					
Bowl Kt/(lbs./Foot)	5.02	5.02	5.02	5.02	5.02	5.02	5.02	5.02	5.02					
Bowl Ka/(lbs.)	88	110	132	154	176	198	220	242	264					
Bowl Shaft Diameter	1-7/16	1-7/16	1-7/16	1-7/16	1-7/16	1-7/16	1-7/16	1-7/16	1-7/16					
Lineshaft Diameter (1)`	1-1/4	1-1/4	1-1/4	1-1/4	1-1/2	1-1/2	1-1/2	1-1/2	1-1/2					
Lineshaft Ks/Foot	4.2	4.2	4.2	4.2	6.0	6.0	6.0	6.0	6.0					
"SDC" Discharge Head Size (2) (3)	16-1/2 x6	16-1/2 x6	16-1/2 x6	16-1/2 x6	16-1/2 x6	N/A	N/A	N/A	N/A					
"LAD" Discharge Head Size (2)	16-1/2 x6	16-1/2 x6	16-1/2 x6	16-1/2 x6	16-1/2 x6	16-1/2 x6	16-1/2 x6	16-1/2 x6	16-1/2 x6					
Column O.D. (in.)	6-5/8	6-5/8	6-5/8	6-5/8	6-5/8	6-5/8	6-5/8	6-5/8	6-5/8					
Column Weight/Foot (lbs.)	18.97	18.97	18.97	18.97	18.97	18.97	18.97	18.97	18.97					
Column Wall Thickness (in.)	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28					

- 1. For setting using more than 50 feet of column and lineshafting, consult the Factory to ensure adequate lineshaft size.
- 2. Discharge heads are equipped with dual registers to accommodate drivers from 10" through 24" BD.
- 3. U.L. Listed Only.



Technical Data

Vertical Turbine Fire Pump

Section **914** Page **107** Date **April 1, 2006**

Supersedes Section 914 Page 107 Dated May 1, 2004

750 GPM 12FCM												
NUMBER OF STAGES	3	4	5	6	7	8	9	10				
Bowl O.D. (in.)	12.26	12.26	12.26	12.26	12.26	12.26	12.26	12.26				
Bowl Kt/(lbs./Foot)	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33				
Bowl Ka/(lbs.)	88.5	118	147.5	177	206.5	236	265.5	295				
Bowl Shaft Diameter	1-11/16	1-11/16	1-11/16	1-11/16	1-11/16	1-11/16	1-11/16	1-11/16				
Lineshaft Diameter (1)`	1-1/4	1-1/4	1-1/2	1-1/2	1-1/2	1-11/16	1-11/16	1-11/16				
Lineshaft Ks/Foot	4.2	4.2	6.0	6.0	6.0	8.1	8.1	8.1				
"LAD" Discharge Head Size (2)	16-1/2 x6											
Column O.D. (in.)	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8				
Column Weight/Foot (lbs.)	24.7	24.7	24.7	24.7	24.7	24.7	24.7	24.7				
Column Wall Thickness (in.)	.277	.277	.277	.277	.277	.277	.277	.277				

750 GPM 14FGM											
NUMBER OF STAGES	3	4	5	6	7	8	9				
Bowl O.D. (in.)	14	14	14	14	14	14	14				
Bowl Kt/(lbs./Foot)	8.41	8.41	8.41	8.41	8.41	8.41	8.41				
Bowl Ka/(lbs.)	112.5	150	187.5	225	262.5	300	337.5				
Bowl Shaft Diameter	1-15/16	1-15/16	1-15/16	1-15/16	1-15/16	1-15/16	1-15/16				
Lineshaft Diameter (1)`	1-1/4	1-1/2	1-1/2	1-11/16	1-11/16	1-11/16	1-15/16				
Lineshaft Ks/Foot	4.2	6.0	6.0	8.1	8.1	8.1	10.6				
"SDC" Discharge Head Size (2)	16-1/2 x8	16-1/2 x8	16-1/2 x8	16-1/2 x8	N/A	N/A	N/A				
"LAD" Discharge Head Size (2)	16-1/2 x8										
Column O.D. (in.)	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8				
Column Weight/Foot (lbs.)	24.7	24.7	24.7	24.7	24.7	24.7	24.7				
Column Wall Thickness (in.)	.277	.277	.277	.277	.277	.277	.277				

- 1. For setting using more than 50 feet of column and lineshafting, consult the Factory to ensure adequate lineshaft size.
- 2. Discharge heads are equipped with dual registers to accommodate drivers from 10" through 24" BD.
- 3. U.L. Listed Only. (750 12 FCM)

Technical Data

Vertical Turbine Fire Pump

	1000 GPM 12FCM											
NUMBER OF STAGES	3	4	5	6	7	8	9					
Bowl O.D. (in.)	12.26	12.26	12.26	12.26	12.26	12.26	12.26					
Bowl Kt/(lbs./Foot)	6.33	6.33	6.33	6.33	6.33	6.33	6.33					
Bowl Ka/(lbs.)	88.5	118	147.5	177	206.5	236	265.5					
Bowl Shaft Diameter	1-11/16	1-11/16	1-11/16	1-11/16	1-11/16	1-11/16	1-11/16					
Lineshaft Diameter (1)`	1-1/4	1-1/2	1-1/2	1-1/2	1-11/16	1-11/16	1-11/16					
Lineshaft Ks/Foot	4.2	6.0	6.0	6.0	8.1	8.1	8.1					
"LAD" Discharge Head Size (2)	16-1/2 x6	16-1/2 x6	16-1/2 x6	16-1/2 x6	16-1/2 x6	16-1/2 x6	16-1/2 x6					
Column O.D. (in.)	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8					
Column Weight/Foot (lbs.)	24.7	24.7	24.7	24.7	24.7	24.7	24.7					
Column Wall Thickness (in.)	.277	.277	.277	.277	.277	.277	.277					

	1000 GPM 14FGM											
Number of Stages	3	4	5	6	7	8	9					
Bowl O.D. (in.)	14	14	14	14	14	14	14					
Bowl Kt/(lbs./Foot)	8.41	8.41	8.41	8.41	8.41	8.41	8.41					
Bowl Ka/(lbs.)	112.5	150	187.5	225	262.5	300	337.5					
Bowl Shaft Diameter	1-15/16	1-15/16	1-15/16	1-15/16	1-15/16	1-15/16	1-15/16					
Lineshaft Diameter (1)`	1-1/4	1-1/2	1-1/2	1-11/16	1-11/16	1-11/16	1-15/16					
Lineshaft Ks/Foot	4.2	6.0	6.0	8.1	8.1	8.1	10.6					
"SDC" Discharge Head Size (2)	16-1/2 x8	16-1/2 x8	16-1/2 x8	16-1/2 x8	N/A	N/A	N/A					
"LAD" Discharge Head Size (2)	16-1/2 x8	16-1/2 x8	16-1/2 x8	16-1/2 x8	16-1/2 x8	16-1/2 x8	16-1/2 x8					
Column O.D. (in.)	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8					
Column Weight/Foot (lbs.)	24.7	24.7	24.7	24.7	24.7	24.7	24.7					
Column Wall Thickness (in.)	.277	.277	.277	.277	.277	.277	.277					

- 1. For setting using more than 50 feet of column and lineshafting, consult the Factory to ensure adequate lineshaft size.
- 2. Discharge heads are equipped with dual registers to accommodate drivers from 10" through 24" BD.
- 3. U.L. Listed Only. (1000 GPM 12 FCM)

THIS PAGE LEFT INTENTIONALLY BLANK



Section **914** Page **108** Date May 1, 2004

Supersedes Section 914 Page 108 Dated June 1, 2001

Technical Data

Vertical Turbine Fire Pump

	1250 GPM 13FGH											
NUMBER OF STAGES	4	5	6	7	8	9	10					
Bowl O.D. (in.)	12.9	12.9	12.9	12.9	12.9	12.9	12.9					
Bowl Kt/(lbs./Foot)	12.02	12.02	12.02	12.02	12.02	12.02	12.02					
Bowl Ka/(lbs.)	173.2	216.5	259.8	303.1	346.4	389.7	433					
Bowl Shaft Diameter	1-11/16	1-11/16	1-11/16	1-11/16	1-11/16	1-11/16	1-11/16					
Lineshaft Diameter (1)`	1-1/2	1-1/2	1-11/16	1-11/16	1-11/16	1-15/16	1-15/16					
Lineshaft Ks/Foot	6	6	8.1	8.1	8.1	10.6	10.6					
"SDC" Discharge Head Size (2)	16-1/2x8	16-1/2x8	16-1/2x8	N/A	N/A	N/A	N/A					
"LAD" Discharge Head Size (2)	16-1/2x8	16-1/2x8	16-1/2x8	16-1/2x8	16-1/2x8	16-1/2x8	16-1/2x8					
Column O.D. (in.)	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8					
Column Weight/Foot (lbs.)	24.7	24.7	24.7	24.7	24.7	24.7	24.7					
Column Wall Thickness (in.)	0.277	0.277	0.277	0.277	0.277	0.277	0.277					

	1500 GPM 13FGH						
NUMBER OF STAGES	4	5	6	7	8	9	10
Bowl O.D. (in.)	12.9	12.9	12.9	12.9	12.9	12.9	12.9
Bowl Kt/(lbs./Foot)	12.02	12.02	12.02	12.02	12.02	12.02	12.02
Bowl Ka/(lbs.)	173.2	216.5	259.8	303.1	346.4	389.7	433
Bowl Shaft Diameter	1-11/16	1-11/16	1-11/16	1-11/16	1-11/16	1-11/16	1-11/16
Lineshaft Diameter (1)`	1-1/2	1-1/2	1-11/16	1-11/16	1-11/16	1-15/16	1-15/16
Lineshaft Ks/Foot	6.0	6.0	8.1	8.1	8.1	10.6	10.6
"SDC" Discharge Head Size (2)	16-1/2 x8	16-1/2 x8	16-1/2 x8	N/A	N/A	N/A	N/A
"LAD" Discharge Head Size (2)	16-1/2 x8	16-1/2 x8	16-1/2 x8	16-1/2 x8	16-1/2 x8	16-1/2 x8	16-1/2 x8
Column O.D. (in.)	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8	8-5/8
Column Weight/Foot (lbs.)	24.7	24.7	24.7	24.7	24.7	24.7	24.7
Column Wall Thickness (in.)	0.277	0.277	0.277	0.277	0.277	0.277	0.277

- 1. For setting using more than 50 feet of column and lineshafting, consult the Factory to ensure adequate lineshaft size.
- 2. Discharge heads are equipped with dual registers to accommodate drivers from 10" through 24" BD.

Technical Data

Vertical Turbine Fire Pump

Section **914** Page **109** Date May 1, 2004

Supersedes Section 914 Page 109 Dated June 1, 2001

2000 GPM 15FGH				
NUMBER OF STAGES	3	4	5	6
Bowl O.D. (in.)	15.0	15.0	15.0	15.0
Bowl Kt/(lbs./Foot)	14.47	14.47	14.47	14.47
Bowl Ka/(lbs.)	160.2	213.6	267	320.4
Bowl Shaft Diameter	1-15/16	1-15/16	1-15/16	1-15/16
Lineshaft Diameter (1)`	1-1/2	1-11/16	1-15/16	1-15/16
Lineshaft Ks/Foot	6.0	8.1	10.6	10.6
"SDC" Discharge Head Size (2) (3)	16-1/2 x10	16-1/2 x10	16-1/2 x10	N/A
"LAD" Discharge Head Size (2)	20x10	20x10	20x10	20x10
Column O.D. (in.)	10-3/4	10-3/4	10-3/4	10-3/4
Column Weight/Foot (lbs.)	31.2	31.2	31.2	31.2
Column Wall Thickness (in.)	0.279	0.279	0.279	0.279

2000 GPM 17FGM				
NUMBER OF STAGES	3	4	5	6
Bowl O.D. (in.)	16.92	16.92	16.92	16.92
Bowl Kt/(lbs./Foot)	21.08	21.08	21.08	21.08
Bowl Ka/(lbs.)	195	260	325	390
Bowl Shaft Diameter	2-3/16	2-3/16	2-3/16	2-3/16
Lineshaft Diameter (1)`	1-11/16	1-15/16	1-15/16	2-3/16
Lineshaft Ks/Foot	8.1	10.6	10.6	13.6
"LAD" Discharge Head Size (2)	20x10	20x10	20x10	20x10
Column O.D. (in.)	12-3/4	12-3/4	12-3/4	12-3/4
Column Weight/Foot (lbs.)	43.77	43.77	43.77	43.77
Column Wall Thickness (in.)	0.330	0.330	0.330	0.330

2500 GPM 15FGH				
NUMBER OF STAGES	3	4	5	
Bowl O.D. (in.)	15.0	15.0	15.00	
Bowl Kt/(lbs./Foot)	14.47	14.47	14.47	
Bowl Ka/(lbs.)	160.2	213.6	267	
Bowl Shaft Diameter	1-15/16	1-15/16	1-15/16	
Lineshaft Diameter (1)`	1-11/16	1-15/16	1-15/16	
Lineshaft Ks/Foot	8.1	10.6	10.6	
"SDC" Discharge Head Size (2) (3)	16-1/2 x10	16-1/2 x10	16-1/2 x10	
"LAD" Discharge Head Size (2)	20x10	20x10	20x10	
Column O.D. (in.)	10-3/4	10-3/4	10-3/4	
Column Weight/Foot (lbs.)	31.2	31.2	31.2	
Column Wall Thickness (in.)	0.279	0.279	0.279	

- 1. For setting using more than 50 feet of column and lineshafting, consult the Factory to ensure adequate lineshaft size.
- 2. Discharge heads are equipped with dual registers to accommodate drivers from 10" through 24" BD.
- 3. U.L. Listed Only. (2000 GPM 15 FGH, 2500 GPM 15 FGH)



Section **914** Page **110** Date **May 1, 2004**

Supersedes Section 914 Page 110 Dated June 1, 2002

Technical Data

Vertical Turbine Fire Pump

3000 GPM 19FGM				
NUMBER OF STAGES	2	3		
Bowl O.D. (in.)	18-3/4	18-3/4		
Bowl Kt/(lbs./Foot)	30	30		
Bowl Ka/(lbs.)	180	260		
Bowl Shaft Diameter	2-3/16	2-3/16		
Lineshaft Diameter (1)`	1-15/16	2-3/16		
Lineshaft Ks/Foot	10.6	13.6		
"SDH" Discharge Head Size	24-1/2x12	24-1/2x12		
Column O.D. (in.)	12-3/4	12-3/4		
Column Weight/Foot (lbs.)	43.77	43.77		
Column Wall Thickness (in.)	0.33	0.33		

3500 GPM 19FGM			
NUMBER OF STAGES	2	3	
Bowl O.D. (in.)	18-3/4	18-3/4	
Bowl Kt/(lbs./Foot)	30	30	
Bowl Ka/(lbs.)	180	260	
Bowl Shaft Diameter	2-3/16	2-3/16	
Lineshaft Diameter (1)`	1-15/16	2-3/16	
Lineshaft Ks/Foot	10.6	13.6	
"SDH" Discharge Head Size	24-1/2x12	24-1/2x12	
Column O.D. (in.)	12-3/4	12-3/4	
Column Weight/Foot (lbs.)	43.77	43.77	
Column Wall Thickness (in.)	0.33	0.33	

4000 GPM 19FGH			
NUMBER OF STAG	ES 2	3	
Bowl O.D. (in.)	18-3/4	18-3/4	
Bowl Kt/(lbs./Foot)	30	30	
Bowl Ka/(lbs.)	180	260	
Bowl Shaft Diameter	2-3/16	2-3/16	
Lineshaft Diameter (1)`	1-15/16	2-3/16	
Lineshaft Ks/Foot	10.6	13.6	
"SDH" Discharge Head Size (2) (3)	24-1/2x12	24-1/2x12	
Column O.D. (in.)	12-3/4	12-3/4	
Column Weight/Foot (lbs.)	43.77	43.77	
Column Wall Thickness (in.)	0.33	0.33	

4500 GPM 19FGH			
NUMBER OF STAGES	2	3	
Bowl O.D. (in.)	18-3/4	18-3/4	
Bowl Kt/(lbs./Foot)	30	30	
Bowl Ka/(lbs.)	180	260	
Bowl Shaft Diameter	2-3/16	2-3/16	
Lineshaft Diameter (1)`	1-15/16	2-3/16	
Lineshaft Ks/Foot	10.6	13.6	
"SDH" Discharge Head Size (2) (3)	24-1/2x12	24-1/2x12	
Column O.D. (in.)	12-3/4	12-3/4	
Column Weight/Foot (lbs.)	43.77	43.77	
Column Wall Thickness (in.)	0.33	0.33	

- 1. For setting using more than 50 feet of column and lineshafting, consult the Factory to ensure adequate lineshaft size.
- 2. Discharge heads are equipped with dual registers to accommodate drivers from 16-1/2" through 24" BD.
- 3. U.L. Listed Only.

Construction Features

Vertical Turbine Fire Pump

Section **914** Page **111** Date June 1, 2001

Supersedes Section 913 Page 111 Dated November 1, 1999

Туре	Vertical Multi-Stage Turbine
Rotation	Counter-clockwise, Viewed from Driven End
Bowls	Diffuser Type, Suction Case and Intermediate Bowls with Wearing Rings,
	Suction Threaded, for Strainer or Flared for Clip On Strainer
Impellers	Enclosed Type, Single Suction
Bearings, Bowl	Sleeve Type, Water Lubricated
Shaft, Bowl	Water Lubricated
Column Pipe	Threaded
Coupling, Column Pipe	Threaded, Sleeve Type
Shaft, Line	Open, Water Lubricated (1)
Coupling, Lineshaft	Thread or Flanged connection, Surface Type (Refer to Factory)
Sleeve, Lineshaft	Straight
Bearing, Lineshaft	Straight, Water Lubricated (1)
Retainer, Bearing	One Piece Cast, Inter-Locked by Column Joints (For open water-lubricated) (1)
Foundation Plate	Suitable for Grouting, with Discharge Head Mounting Surface
Discharge Head	Flanged Connection, Surface Type
Stuffing Box	Packed, with Bushing and Seal Tap
Gland	One Piece
Auxiliary Connections,	Heat Exchanger and Packing Box Drain
Discharge Head	
Coupling, Driver	Gib Key with Locknut
Strainer	Threaded, Basket or Cornucopia; Clip-On Basket


⁽¹⁾ Oil lubricated when static water level is 50 to 200 feet below datum. Water level datum greater than 200 feet is not approved for fire pump service.

Section **914** Page **112** Date **June 1, 2002**

Supersedes Section 914 Page 112 Dated June 1, 2001

Assembly Drawing

Vertical Turbine Fire Pump



10FEM, 11FGM, 12FCM, 13FGH, & 15FGH SDC Discharge Head — Water Lubrication Only


ITEM	DESCRIPTION	MATERIAL
1	Adjusting Nut	Steel
6	Water Slinger	Neoprene
7	Discharge Head	Cast Iron
8	Capscrew, Packing Box	Steel Gr. 2
9	Gland Half	Bronze
11	Gasket, Packing Box	Tag Board
12	Pre Lube Plug (2)	Cast Iron
13	Sleeve, Top Shaft	Stainless Steel
14	Foundation Plate	Cast Iron
15	Packing	Syn. Graphite Impreg.
17	Packing Box	Cast Iron
17A	Bushing, Packing Box	Bronze
19	Top Shaft	Steel
21	Column Pipe, Top	Steel
22	Coupling, Lineshaft	Steel
23	Lineshaft	Steel
24	Coupling, Column	Steel
25	Bearing Retainer	Bronze
26	Bearing	Neoprene
28	Column Pipe, Intermediate	Steel
29	Sleeve, Intermediate Shaft	Stainless Steel
30	Column Pipe, Bottom	Steel
31	Coupling, Pump Shaft	Steel
32	Pump Shaft	Stainless Steel
34	Bearing, Top Bowl	Bronze
35	Bearing, Intermediate Bowl	Bronze
36	Bowl, Intermediate	Cast Iron
38	Impeller	Bronze
39	Lock Collet, Impeller	Steel
40	Bell, Suction	Cast Iron
41	Bearing, Suction Bell	Bronze
42	Strainer	Bronze
42A	Clip, Strainer	Bronze
54A	Flange, Adapter	Cast Iron
55	Bowl, Top	Cast Iron
58	Sand Collar	Steel
59	Plug, Suction Bell	Cast Iron
88	Set Screw, Sand Collar	Steel
98	Bowl, Wear Ring	Bronze

Sectional Drawing

Vertical Turbine Fire Pump

Section **914** Page **113** Date **June 1, 2001**

Supersedes Section 913 Page 113 Dated November 1, 1999



10FEM, 11FGM, 12FCM, 13FGH, & 15FGH LAD Discharge Head — Water Lubrication Only

ITEM	DESCRIPTION	MATERIAL
1	Adjusting Nut	Steel
6	Water Slinger	Neoprene
7	Discharge Head	Cast Iron
8	Capscrew, Packing Box	Steel Gr. 2
9	Gland Half	Bronze
11	Gasket, Packing Box	Tag Board
12	Pre Lube Plug (2)	Cast Iron
13	Sleeve, Top Shaft	Stainless Steel
14	Foundation Plate	Cast Iron
15	Packing	Syn. Graphite Impreg.
16	Gasket, Top Flange	Tag Board
17	Packing Box	Cast Iron
17A	Bushing, Packing Box	Bronze
18	Flange, Top Column	Cast Iron
19	Top Shaft	Steel
21	Column Pipe, Top	Steel
22	Coupling, Lineshaft	Steel
23	Lineshaft	Steel
24	Coupling, Column	Steel
25	Bearing Retainer	Bronze
26	Bearing	Neoprene
28	Column Pipe, Intermediate	Steel
29	Sleeve, Intermediate Shaft	Stainless Steel
30	Column Pipe, Bottom	Steel
31	Coupling, Pump Shaft	Steel
32	Pump Shaft	Stainless Steel
34	Bearing, Top Bowl	Bronze
35	Bearing, Intermediate Bowl	Bronze
36	Bowl, Intermediate	Cast Iron
38	Impeller	Bronze
39	Lock Collet, Impeller	Steel
40	Bell, Suction	Cast Iron
41	Bearing, Suction Bell	Bronze
42	Strainer	Bronze
42A	Clip, Strainer	Bronze
54A	Flange, Adapter	Cast Iron
55	Bowl, Top	Cast Iron
58	Sand Collar	Steel
59	Plug, Suction Bell	Cast Iron
88	Set Screw, Sand Collar	Steel
98	Bowl, Wear Ring	Bronze



Section **914** Page **114** Date **April 1, 2006** Supersedes Section 913 Page 114 Dated June 1, 2001

THIS PAGE LEFT INTENTIONALLY BLANK




Assembly Drawing

Vertical Turbine Fire Pump

Section **914** Page **115** Date June 1, 2001

Supersedes Section 913 Page 115 Dated November 1, 1999



19FGM & 19FGH SDH Discharge Head — Water Lubrication Only

ITEM	DESCRIPTION	MATERIAL
1	Adjusting Nut	Bronze
6	Water Slinger	Neoprene
7	Discharge Head	Cast Iron
8	Capscrew, Packing Box	Steel Gr. 2
9	Gland Half	Bronze
11	Gasket, Packing Box	Tag Board
12	Pre Lube Plug	Cast Iron
14	Foundation Plate	Cast Iron
15	Packing	Acrylic
16	Gasket, Top Flange	Tag Board
17	Packing Box	Cast Iron
17A	Bushing, Packing Box	Bronze
18	Flange, Top Column	Cast Iron
19	Top Shaft	Stainless Steel
21	Column Pipe, Top	Steel
22	Coupling, Lineshaft	Steel
23	Lineshaft	Steel
24	Coupling, Combination	Cast Iron
26	Bearing	Neoprene
28	Column Pipe, Intermediate	Steel
29	Sleeve, Intermediate Shaft	Stainless Steel
30	Column Pipe, Bottom	Steel
31	Coupling, Pump Shaft	Steel
32	Pump Shaft	Stainless Steel
34	Bearing, Top Bowl	Bronze
35	Bearing, Intermediate Bowl	Bronze
36	Bowl, Intermediate	Cast Iron
38	Impeller	Bronze
39	Gib Key, Impeller	Stainless Steel
40	Bell, Suction	Cast Iron
41	Bearing, Suction Bell	Bronze
42	Strainer	Bronze
42A	Machine Screw, Strainer	Stainless Steel
54A	Flange, Adapter	Cast Iron
55	Bowl, Top	Cast Iron
58	Sand Collar	Rubber
59	Plug, Suction Bell	Cast Iron
98	Bowl, Wear Ring	Bronze



Section **914** Page **116** Date **June 1, 2001**

Supersedes Section 913 Page 116 Dated November 1, 199p

Material Specifications

Vertical Turbine Fire Pump

ITEM	DESCRIPTION	MATERIAL	SPECIFICATION		
1	Adjusting Nut	Steel	A108GR12L14		
6	Water Slinger	Neoprene	Commerical		
7	Discharge Head	Cast Iron	A48-CL30		
8	Packing Capscrew	Steel Grade 2	Commercial		
9	Gland Half	Bronze	B584 AL836		
11	Gasket Packing Box	Tag Board	Commercial		
12	Pre-Lube Plug (2)	Cast Iron	Commercial AISI 304		
13	Sleeve Top Shaft	eve Top Shaft Stainless Steel			
14	Floor Plate	Cast Iron	A48-CL30		
15	Packing	Syn. Graphite Impreg.	Syn. Graphite Impreg. Commercial		
16	Gasket Top Flange	Tag Board			
17	Packing Box	Cast Iron	st Iron A48-CL30		
17A	Bushing Packing Box	Bronze	B505 AL932		
18	Flange Top Column	Cast Iron	A48-CL30		
19	Top Shaft	Steel	AISI 1045		
21	Top Column Pipe	Steel	A53 or A120		
22	Coupling Lineshaft	Steel	A108 GR12L14		
23	Lineshaft	Steel	AISI 1045		
24	Coupling Column	Steel	A53 or A120		
25	Bearing Retainer	Bronze	B584 AL836		
26	Bearing	Neorprene	Commercial		
28	Column Pipe, Intermediate	Steel	A53 or A120		
29	Sleeve Intermediate Shaft	Stainless Steel	AISI 304		
30	Column Pipe, Bottom	Steel	A53 or A120		
31	Coupling Pump Shaft	Steel	A108 GR12L14		
32	Pump Shaft	Stainless Steel	AISI 416		
34	Bearing Top Bowl	Bronze	B505 AL932		
35	Bearing Intermediate Bowl	Bronze	B505 AL932		
36	Bowl Intermediate	Cast Iron	A48-CL30		
38	Impeller	Bronze (3)	B584 AL836		
39	Lock Collet Impeller	Steel	A108 GR12L14		
40	Bell Suction	Cast Iron	A48-CL30		
41	Bearing Suction Bell	Bronze	B505 AL932		
42	Strainer	Brass	Commercial		
42A	Clip, Strainer	Brass	Commercial		
54A	Flange Adapter	Cast Iron	A48-CL30		
55	Top Bowl	Cast Iron	A48-CL30		
58	Sand Collar	Steel	A108 GR12L14		
59	Plug Suction Bell	Cast Iron	Commercial		
88	Set Screw, Sand Collar	Steel	SAE Bolt Steel		
98	Bowl Wear Ring	Bronze	B505 AL932		
	<u>-</u>				

NOTE:

- 1. All material specifications are ASTM except where specified and are for description of chemistry only.
- 2. When applied with diesel engine driver, remove plug and connect to engine heat exchanger for cooling water.
- 3. Manufacturer's option to furnish bronze, per B548-AL875.

Subject to change without notice.



Typical Specifications

Section **914** Page **117** Date **June 1, 2001**

Vertical Turbine Fire Pump

Motor Driven

A standard length (type SL) flexible drive shaft is required to connect the fire pump engine to the right angle gear when applied with a vertical turbine pump. To select the correct shaft size:

- 1. Select the engine speed in the left hand column.
- 2. Follow the row to the right to a horsepower value which meets or exceeds the requirements of your application. (Note: These values include a 2.0 service factor, angle not to exceed 3 degrees, and a B-10 bearing life expectation of 2500 hours.
- 3. Follow the column up to select the correct shaft size.

		SHAFT SIZE SERIES							
		48	55	61	71	81	88	91	
	1750	103	132	201	274	382	527	744	
	1900	108	138	211	286	401	553		
Fi.	2100	116	149	227	309	430	594	838	
Engine Speeds	2200	120	154						
Speeus	2300	124	158	242	330	459	633		
	2400	127	163						
	2600	135	173						
	2800	142	182						
	3000	149	191						
Standard Shaft Length		24"	24"	24"	24"	36"	36"	36"	

Section **914** Page **118** Date **June 1, 2001**

THIS PAGE LEFT INTENTIONALLY BLANK