

SUBMERSIBLE SOLIDS HANDLING PUMPS

MNG SERIES

GENERAL

Furnish Myers® MNG series solids handling submersible sewage pump(s) as specified herein.

Pump shall be equipped with stainless steel nameplate, stating the unit is accepted for use in Standard Location or NEC® class 1, Division 1, Groups C, D hazardous locations with third party, Factory Mutual, approval.

The pump shall be non-overloading throughout operation without employing service factor. The performance curve submitted for approval shall state in addition to head and capacity performance, the pump efficiency, and reflect motor service factor.

Job Name: _____

- ◆ Pump: Myers MNG _____
- ◆ Number of Pumps: _____
- ◆ Impeller: _____
- ◆ Discharge: Shall be _____" ANSI flange.
- ◆ Motor: Shall be _____ HP _____ V _____ Hz _____ Phase, Oil Filled Design.
- ◆ Power Cord: Shall be epoxy potted and equipped with a minimum of 35' of power cord.
- ◆ Pump Operating Characteristics: Each pump shall be verified for performance. Pump Shall operate at following conditions:
 - 0 ___ GPM at ___ TDH
 - ___ GPM at ___ TDH
 - ___ GPM at ___ TDH
 - ___ GPM at ___ TDH

CONSTRUCTION

- ◆ **Castings** – Cord Cap / Motor Housing / Bearing Housing / Seal Plate shall be ASTM A48 Class 30 Cast Iron.
- ◆ **Shaft** shall be 416 Stainless Steel.
- ◆ **Impeller** - ASTM A536 Ductile Iron Class 80.
- ◆ **Fasteners / Hardware** shall be 300 series Stainless Steel.
- ◆ **Elastomers – O-Rings / Mechanical Seals / Cord Grip Grommets** shall be Nitrile with optional Fluoropolymer Elastomer.
- ◆ **Dual Mechanical Seals** shall be Carbon / Silicon Carbide.
- ◆ **Power Cable** shall be type S00W or W while Control Cable shall be S00W.
- ◆ **Lifting Bail** shall be welded or forged 300 Series Stainless.

ELECTRICAL POWER CORD

The power cord will be SOOW or W, oil and water resistant 600v, 90C, UL® and CSA® approved and applied per NEC ampacities ratings at the cables rated temperature for intermittent / continuous duty. The pump shall be double protected with a compression fitting and an epoxy potted area that seals each conductor at the power cord entry to the pump. The power cable entry into the cord cap assembly shall first be made with a compression fitting. The leads shall be terminated within the epoxy and mechanically crimped to Teflon leads. This area of the cord cap shall then be filled with an epoxy compound potting. This assembly will prevent water contamination from gaining entry even in the event of wicking or capillary action. The power cord leads shall be connected to the motor leads with a terminal block or extra heavy connectors. The cord cap assembly where bolted to the motor housing shall be sealed with a Nitrile O-ring on a beveled edge to assure proper sealing. Wiring connection shall be done through a terminal block eliminating wire nuts or use of heavy duty crimp connectors.

MOTOR

With exception of 208V models, motors shall meet premium efficiency in accordance with IEC 60034-30, level IE3, and NEMA MG1 [NEMA 12.60 Enclosed motor]. The motors are submerged in non-toxic, oil filled, cool running design providing significantly reduced operating temperatures. Pump designs requiring a secondary cooling apparatus shall be deemed unapproved and not equal. Air filled pump designs shall not be considered equal or approved.

- ◆ Motor will be of the squirrel-cage induction design, NEMA type A or B for 3 Phase [Per NEMA MG1 1.19].
- ◆ The copper stator windings shall be insulated with moisture resistant Class H insulation materials, rated for 180°C (356°F) [Per NEMA MG1 1.66].
- ◆ The service factor shall be 1.15 for all models excluding the highest HP per frame size, which will be at 1.0. The motor shall have a voltage tolerance of +/- 10% from nominal, and a phase to phase voltage imbalance tolerance of 1%.
- ◆ The rotor bars and short circuit rings shall be made of cast aluminum.
- ◆ The maximum continuous temperature of the pumped liquid shall be 40°C (104 F). Each of the three phases will have a UL/FM approved thermostat or thermistor. The winding operating temperature at rated horsepower and service factor will be a maximum of 130°C @ 40°C ambient.
- ◆ The motor shall be capable of handling up to 15 evenly spaced starts per hour without overheating [Per NEMA].
- ◆ The rotors will have high efficiency laminated steel with die cast bars and shorting rings. The stators will have high efficiency laminated steel (if required to meet premium efficiency), with inverter duty rated, Class H magnet wire & insulation materials. Each of the three phases will have a UL/FM approved thermostat or thermistor set for 130°C +/-5.

BEARINGS

The upper bearing shall be a heavy-duty radial single row ball bearing while the lower bearing shall be a double row heavy-duty angular contact ball bearing of the thrust limiting design. Minimum of 50,000 hours per ISO 281 bearing life for radial and thrust bearings at BEP. Any pump having rated B10 life only at the BEP shall not be considered equal or approved. Bearing shall be lubricated for life from the factory and will be accomplished through the non-toxic, low viscous, dielectric oil in the frame. Pump designs requiring periodic scheduled bearing service shall not be considered equal or approved. Single row or sleeve lower bearings shall not be acceptable.

SHAFT

The pump shaft shall be an integral, one piece unit adequately designed to meet the maximum torque required at any normal start up condition or operating point in the system. Shafts of carbon steel, chrome plated or spin welded shafts shall not be considered adequate or equal. Material of shaft shall be 416 stainless steel conforming to ASTM 8582.

FLUID END

The impeller shall be through hardened ASTM A536 Ductile Iron Class 80. Optional coatings available for improved corrosion resistance. The impeller mounting is to be a slip fit onto a tapered shaft and a drive key. The impeller shall be attached to the shaft by a SST fastener. The impeller is to be balanced to ISO1940-1 Grade G6.3 standard. Impeller designs that rely on fins or pins protruding into the suction path to assist in the handling of fibrous material shall not be considered equal. Impellers shall be of the semi-open type having the ability to pass a wide range of solids. Any impeller design requiring mechanical bypass mechanism located in the volute in order to handle solids shall not be considered equal or acceptable.

The volute shall be ASTM Class 30. It will consist of a centerline discharge one piece design with the ability to install a mix flush. The discharge flange shall be ANSI Class 125 and be integrated into the volute case.

SEALS

Each pump will be equipped with a tandem mechanical seal design. The configuration of the lower seal shall be of the type 2 design and constructed of Carbon/ Silicon Carbide and be replaceable without disassembly of the seal chamber. The upper seal shall be of the type 2100 design and constructed of Carbon/Silicon Carbide. Each seal will not require routine maintenance or adjustment.

EQUIPMENT MONITORING

The integrity of the seal system shall be continuously monitored during pump operation and standby time. Two electrical probes shall be provided in a sensing chamber for detecting the presence of water contamination within the chamber. The sensing chamber shall be fitted with environmentally safe nontoxic oil. A solid state relay mounted in the pump control panel or in a separate enclosure shall send a low voltage, low amperage signal to the probe, continuously monitoring the conductivity of the liquid in the sensing chamber. If sufficient water enters the sensing chamber, the probe shall sense the increase in conductivity and signal the solid state relay in the control panel. The relay shall then energize a warning light on the control panel, or optionally, cause the pump to shut down.

This system shall provide an early warning of seal leakage, thereby preventing further damage to the submersible pump and allowing scheduled rather than emergency maintenance. Systems utilizing float switches or any other monitoring devices located in the stator housing rather than in a sensing chamber between the seals are not considered to be early warning system, and shall not be considered equal.

SERVICEABILITY

The motor housing, seal housing with seal plate and impeller still attached to the shaft shall be capable of being lifted out of the volute case from the top as one assembly. For ease of repair, the motor stator shall be securely held in place by an end ring so it can be easily removed without the use of heat or a press.

MYERS SUBMERSIBLE SOLIDS HANDLING PUMPS

TESTING

All pumps shall be built in a dedicated domestic factory with sixty years of continuous operation. All pumps shall be visually inspected to confirm they are built in accordance with the specification as to HP, voltage, phase and hertz. The motor housing will be filled with dielectric oil and shall be allowed to run dry to check for proper rotation. Discharge piping shall be attached, the pump submerged in water, and amp readings shall be taken on each phase to verify balanced stator windings. All pumps shall receive standard Hydraulic Institute (HI) non-witnessed testing at a third-party agency-certified test lab.

PAINT

The pump shall be painted with waterborne hybrid acrylic/alkyd paint. This custom engineered, quick dry, low VOC paint shall provide superior levels of corrosion and chemical protection. Optional coatings of chlorinated rubber, coal tar epoxy and polyamide epoxy are available through the factory.



1101 Myers Parkway
Ashland, OH 44805, USA
Ph: 855.274.8948
Fx: 800.426.9446

490 Pinebush Road, Unit 4,
Cambridge, Ontario N1T 0A5, Canada
Ph: 800.363.7867
Fx: 888.606.5484

pentair.com/myers

UL and the UL logo are trademarks of UL LLC.
CSA is a registered trademark of CSA Group. All rights reserved.
NEC is the registered trademark of National Fire Protection Association, Inc.

All indicated Pentair trademarks and logos are property of Pentair. Third party registered and unregistered trademarks and logos are the property of their respective owners.

©2024 Pentair. All Rights Reserved.

MY12735 (01-16-24)